

**CITY OF FORT SMITH SUPPLEMENTAL SPECIFICATION  
EXCAVATION AND EMBANKMENT**

**SECTION 203** of the Standard Specifications for Public Works Construction, October 2018 Edition, is hereby amended as follows:

**203.03 CLASSIFICATION**

The third paragraph of this subsection shall be deleted and replaced with the following:

“Select Material” shall consist of excavation made from borrow areas outside the limits of the project. It shall be the Contractor’s responsibility to locate and obtain the select material subject to the approval of the Engineer. Select material shall be granular, maximum particle size of 3 inches, graded from coarse to fine, conforming to AASHTO classification A-1, A-2-4 or A-2-5, or a sandy or gravely clay conforming to classification A-2-6 or A-6 with the exception that the plasticity index shall not exceed 15. Select material shall also have a minimum CBR value of 10. Crusher screenings and non-plastic materials will not be allowed as Select Material. The Contractor shall furnish, at his expense, test data to indicate compliance of select material with this specification. “Select Material” shall only be used if the Contractor demonstrates to the Engineer that no suitable On-Site Borrow is available. Select Material will also be used if shown on the plans or as directed by the Engineer.